


## NOTES: 3

- 1) BRACKET WEIGHT 9 lbs (4 kg).
- 2) MAXIMUM ALLOWABLE LOADING: DEAD LOAD 50 lbs (22.7 kg), EPA 2 sq.ff (0.19 sq.m).
- 3) THE BRACKET CAN ACCOMMODATE EITHER ACORN OR COBRA HEAD LUMINAIRE.

DISTRIBUTION CONSTRUCTION STANDARD Street Lighting			LANEWAY LIGHTING BRACKET						
TOR		Approved By: J.D. 201	6-07-26	ACORN OR COBRA HEAD LUMINAIRE ON WOOD POLE				IMINAIRE	
	/ HYDRO	Drafted By:	Designed By: J.D./E.H.	Original Issue:	2001-01-05	Scale: N.T.S.	Rev: 3	30-9100	1/2



BOM LEGEND								
А	COBRA HEAD							
В	ACORN							

## <u>A</u>

	BILL OF MATERIALS FOR 30-9100								
ITEM	DESCRIPTION		ITEM	Q	ΓΥ				
NO.	DESCRIPTION	I.D.	A	В					
1	BRACKET ALUMINUM 1 <sup>5</sup> / <sub>8</sub> " O.D.		7900022	1	1				
2	LAG SCREW <sup>5</sup> / <sub>8</sub> " X 5"		2550030	1	1				
	OPEN BIN MATERIALS ************************************	XXXX		XXXX	>>>>				
3	BOLT MACHINE $^{5}/_{8}$ " X 12" C/W SQUARE HEAD AND NUT		2510190	1	1				
4	WASHER CURVED 2" X 2" FOR 5/8" BOLT		2530020	1	1				
5	WASHER 2" X 2" FOR 5/8" BOLT		2530003	2	2				
	ASSOCIATED STANDARDS ************************************	XXXX		XXXX	x				
6	COBRA HEAD LUMINAIRE SELECTION TABLE S	STD.	30-1110	1	_				
7	ACORN LUMINAIRE SELECTION TABLE	STD.	30-1120	_	1				
8	O/H SUPPLY TO POLE-MOUNTED LUMINAIRE	STD.	30-3600	1	1				

DISTRIBUTION CC Stre	NSTRUCTION et Lighting	STANDARD	LANEWAY LIGHTING BRACKET							
TORONTO	Approved By: J.D. 201	6-07-26		ACORN OR COBRA HEAD LUMINAIRE ON WOOD POLE						
HYDRO	Drafted By:	Designed By: J.D./E.H.	Original Issue	: 2001-01-05	Scale: N.T.S	Rev:	3	30-9100	2/2	